

Laboratory: „F Plus“ OOD, ul. „Vitosha“, 2042 Kostenets, Sofiiska oblast  
Office: bul. „Al.Stamboliyski“ 205, sgrada B, floor 3, off. 306B, Sofia 1000  
Telephone: +359 878 112 112; e-mail: office@fplus-eu.com; www.fplus-eu.com

Out № 725  
from 21.07.2025

**To  
The representatives of  
Alban Giacomo Spa**

On 04.02.2025 a fire resistance test was conducted on the doorset "Fortis EI60". The fire impact was bilateral. Test duration was 63 minutes.

The thermal insulation criteria were fulfilled for 64 minutes, integrity was maintained for 63 minutes.

Fortis EI60 is a hinged door made from timber and derived timber products, classified EI<sub>1</sub>; EI<sub>2</sub> 60. The dimensions of the door leaves were (W x H) 2200 mm x 1000 mm with an overall thickness of the door leaf of 56 mm.

The suitability of Opera Hotel SL lock, model B505017034, produced by the company Alban Giacomo SPA– Italy for installation in this door construction has been successfully verified by the fire resistance test as per EN 1634-1 for a test duration of 60 minutes.

For further details refer to the test report TR-459-01/05.05.2025 issued by F Plus ltd.

Additional information will be given in final reports issued from Fplus Testing and Research Laboratory.

With respect,  
Head of Laboratory  
"Fplus" fire tests:

.....  
/Assoc. Proff. Eng. Detelin Spassov, PhD/

21.07.2025